



July 30, 2020

Mr. Richard de Campo
Poss Architecture
Reference Owl Creek Town Homes

Dear Richard,

As a follow up to our meeting earlier this week. CeDUR approves your application of Ice and Water Shield in lieu of Standard Underlayment (Asphalt or Synthetic) and Interply. We also approve the Ice and Water Shield under our ridge cap. Our warranty will be in full effect for these applications.

Best Regards,

Dave

Sincerely

Dave Dalton

Chief Operating Officer



CeDUR Roofing Shakes

3590 Himalaya Rd Aurora, CO 80011

Office: 720-974-9200

Direct: 720-974-9202

3590 Himalaya Road • Aurora • Colorado • 80011
Toll Free (844) 974-9196 • Local (720) 974-9200 • Fax (720) 974-3193
info@cedur.com • www.cedur.com